

NAME: CITY OF BLANCO TX0160002
ID: TX0160002

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Maximum Contaminant for Total Trihalomethanes TTHMs

The U.S. Environmental Protection Agency (U.S. EPA) has established Maximum Contaminant Level (MCL/MRDL) for all TTHM contaminants in milligrams per liter (mg/L) and has determined that it is a health concern at levels above the 0.080 mg/l MCL/MRDL. Below is the table of all the contaminant(s) we exceeded and their corresponding values and monitoring periods.

Contaminant(s)	MCL/MRDL	Our Compliance Value	Monitoring Period
TTHM	0.080mg/l	0.085mg/l	Q1 2025

Potential adverse health effects

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

What should I do?

There is nothing you need to do at this time. You may continue to drink the water. However, if you have health concerns, you may want to talk to our doctor to get more information about how this may affect you.

What is being done?

We are analyzing resources to reduce the TTHMs

For more information, please contact:

PWS Contact Name: Danny Maldonado -Inframark_____

Phone: 830-554-0589_____ **Email: dmaldonado2@inframark.com**_____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date distributed: 09/29/2025